



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

SealBoss Corporation
1669 E Wilshire Avenue
Santa Ana, CA 92705, United States

Plant Location:

Santa Fe Springs, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2020

Certificate:

Issued Date: 12/07/2021

Material/Product:

SealBoss 1570 WaterStopFoam F

Contact Temperature:

23 ± 2°C

Models:

SealBoss 1570 WaterStopFoam F

SealBoss 1570 WaterStopFoam F is a drinking water system component in accordance with standard NSF/ANSI 61 Section 5 when properly mixed with SealBoss 15X Accelerator.

SealBoss 15X Accelerator is a drinking water system component in accordance with standard NSF/ANSI 61 Section 5 when properly mixed with SealBoss 1570 WaterStopFoam F.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum tank size (gallons): 200,000

Maximum tank surface area/volume ratio (sq in/L): 0.97

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 5 min / 77 ± 5 °F up to 24 hr / 77 ± 5 °F

Mix ratio: 10:1:1 by weight (SealBoss 1570: SealBoss 15X Accelerator : Water)

Colors: Original

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

The Surface area of the product that touches water should not exceed more than 1% coverage of the total surface area.

Maximum crack fill width on a normal run = 0.25 inches.

Flush for a minimum 15 seconds at approximately 3 gpm at ambient temperature.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.