



TRUESDAIL LABORATORIES, INC.

# Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

SealBoss Corporation  
1669 E Wilshire Avenue  
Santa Ana, CA 92705

**Plant Location:**

Santa Fe Springs, CA

**Standards:**

NSF/ANSI 61 (2014a) Section 5

**Certificate:**

Issued: 01/15/2016  
Expires: 12/31/2021

**Material/Product:**

Crack Fillers

**Contact Temperature:**

23 ± 2 °C


**Models:**

SealBoss 1570LV WaterStopFoam

SealBoss 1570LV WaterStopFoam is a drinking water system component in accordance with standard NSF/ANSI 61 Section 5 when properly mixed with SealBoss 15X Accelerator. <sup>(1)</sup>

SealBoss 15X Accelerator is a drinking water system component in accordance with standard NSF/ANSI 61 Section 5 when properly mixed with SealBoss 1570LV WaterStopFoam. <sup>(1)</sup>

Note <sup>(1)</sup> See next page for additional information and restrictions.



THIS CERTIFICATION MARK MAY BE  
APPLIED TO THE APPROVED PRODUCTS  
AND TO THEIR PACKAGING OR  
DESCRIPTIVE LITERATURE



ANSI Accredited Program  
PRODUCT CERTIFICATION  
ID #0303



**ADDITIONAL INFORMATION**

**Company**

SealBoss Corporation

Contact

Technical Support

Phone

(714) 662-4445

**Product Description**

Crack Fillers

Brand Name/Model No.

SealBoss 1570LV WaterStopFoam

**Material Characteristics**

Minimum Tank size (gallons):

-----

Max Surface Area/Vol ratio (sq in/L) in Tank:

1.2

Method of how to prepare this application:

Refer to manufacturer's instruction for details.

Is Coating required (i.e. primer, Intermediate Coat, Top Coat, and thinner)

No

Number of Coats <sup>(1)</sup>

Minimum 1 pass

Description of substrate preparation (including use of specific thinner):

None

Dry Film Thickness (cm) <sup>(1)</sup>

1.0

Re-coat dry time/temperature:

NA

Total cure time/temperature:

24 hours at max 80 °F

Mix Ratio:

A:B:C (10:1:1) by volume

Comments:

Refer to manufacturer's instruction for details.

**WATER CONTACT RESTRICTION**

Contact Temperature

23 ± 2 °C


Contact Material:

Water

Note (1) : As Tested

**FORMULA:**

**Maximum Surface Area Usage = 0.0452 X Containment Size in Gallons**



THIS CERTIFICATION MARK MAY BE APPLIED TO THE APPROVED PRODUCTS AND TO THEIR PACKAGING OR DESCRIPTIVE LITERATURE



ANSI Accredited Program  
PRODUCT CERTIFICATION  
ID #0303