



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

SealBoss Corporation
1669 E Wilshire Avenue
Santa Ana, CA 92705, United States

Plant Location:

Santa Fe Springs, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2020

Certificate:

Issued Date: 04/15/2019

Material/Product:

SealBoss FlexGel System

Contact Temperature:

23 ± 2°C

Models:

SealBoss FlexGel System



Material Characteristics:

Minimum tank size (gallons): 20,000

Maximum tank surface area/volume ratio (sq in/L): 2.1

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 5 min / 77 ± 5 °F up to 24 hr / 77 ± 5 °F

Mix ratio: 1:8 by weight (1:10 Max; SealBoss FlexGel : Water)

Colors: Original

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Maximum crack fill width (inch) on a normal run: 0.25

Flushing, preparation, or application instruction prior to use:

Normal flush for a minimum 15 seconds at approximately 3 gpm water at ambient temperature.

The surface area of the product that touches water should not exceed more than 0.1% coverage of the total surface area.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.